



Product Service

Attestation of Conformity

No. N8A 072573 0052 Rev. 00

Holder of Certificate: **FOSHAN GUANGTENG NEW ENERGY CO.,LTD**

Section 2, Yongfeng Industrial Zone
Lunjiao, Shunde,
528308 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Product: **Heat pumps
(DC INVERTER HEAT PUMP)**

Model(s): **GT-SKR050KBDC-M32, GT-SKR050KBDC-S32**

Parameters:

Rated Voltage:	380-415V, 3N~
Rated Frequency:	50Hz
Rated current:	12A
Protection Class:	Class I
Degree of Protection:	IPX4
Refrigerant:	R32/2200g

Tested according to:

EN 60335-1:2012/A2:2019
EN 60335-2-40:2003/A13:2012
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111200523901

Date, 2021-01-15

(Sam Yang)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.