Energy labelling Regulation: (EU) 811/2013 Ecodesign Regulation: (EU) 813/2013

## PRODUCT FICHE

	eater	No label found for GT-SKR015KBDC-S faw.heatpump.single.	
Space Heating	Energy efficiency class 55°C (High temp. app.) Energy efficiency class 35°C (Low temp. app.)	-	A++ A++
Average climate (Design temperature = -10°C)	Energy entriency class 55 0 (cow temp. app.)		
Space heating 55°C	Prated (declared heating capacity) @ -10°C	[kW]	4.52
	Seasonal space heating efficiency (n <sub>S</sub> )	[%]	125.8
	Annual energy consumption	[kWh]	2900
Space heating 35°C	Prated (declared heating capacity) @ -10°C	[kW]	5.52
	Seasonal space heating efficiency $(\eta_S)$	[%]	157.6
	Annual energy consumption	[kWh]	2838
off peak operation function integrated in Heat pump		Y/N	N
Colder climate (Design temperature = -22°C) Space heating 55°C	Prated (declared heating capacity) @ -22°C	[kW]	3.52
	· · · · · · · · · · · · · · · · · · ·	[%]	98.1
	Seasonal space heating efficiency (η <sub>S</sub> )		
Space heating 35°C	Annual energy consumption	[kWh] [kW]	2877 4.52
	Prated (declared heating capacity) @ -22°C		
Warmer climate (Design temperature = 2°C)	Seasonal space heating efficiency $(\eta_{\hat{S}})$	[%]	122.9
	Annual energy consumption	[kWh]	2966
Space heating 55°C	P+ I (declared heating canacity) @ 2°C	[kW]	6.52
	Prated (declared heating capacity) @ 2°C	[%]	163.5
	Seasonal space heating efficiency $(\eta_S)$		
Space heating 35°C	Annual energy consumption	[kWh] [kW]	3235 7.25
	Prated (declared heating capacity) @ 2°C		
	Seasonal space heating efficiency $(\eta_{\mbox{\scriptsize S}})$	[%]	204.9
	Annual energy consumption	[kWh]	2989
Sound Power (*)		[dB(A)]	59
Ecodesign technical data Product description	Air-to-water heat pump:	Y/N	Yes
	Water-to-water heat pump:	Y/N	No No
	Brine-to-water heat pump:  Low-temperature heat pump:	<u>Y/N</u> <u>Y/N</u>	No No
	Equipped with a supplementary heater:	Y/N	No
Air to water unit	For heat pump combination heater:  Rated airflow (outdoor)	Y/N [m3/h]	No 1900
Brine/water to water unit	Rated water/brine flow (outdoor H/E)	<sub>[m</sub> 3 <sub>/h]</sub>	
Other	Capacity control	- [III /II]	Inverter
Suite	P <sub>Off</sub> (Power consumption Off mode)	[kW]	0.020
	•	[kW]	0.020
	P <sub>to</sub> (Power consumption Thermostat off mode)	<u> </u>	
	P <sub>Sb</sub> (Power consumption Standby mode)	[kW]	0.020
	PCK (Power crankcase heater model)	[kW]	0.038
	Q <sub>EIEC</sub> (Daily electricity consumption)	[kWh]	/
	••••	[IAMb]	/
	Q <sub>fue</sub> (Daily fuel consumption)	[kWh]	7
		TLAND	4.00
	P <sub>dh</sub> (declared heating capacity)	[kW]	4.88
	P <sub>dh</sub> (declared heating capacity)  COP <sub>d</sub> (declared COP)	[kW]	4.88 3.09
(A) condition (-7°C)		-	3.09
A) condition (-7°C)	COPd (declared COP)	[kW] - - [kW]	3.09
A) condition (-7°C)	COP <sub>d</sub> (declared COP)  Cdh_(degradation coefficient)  Pdh_(declared heating capacity)	-	3.09
A) condition (-7°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)	-	3.09 0.00 3.40 4.03
A) condition (-7°C)  B) condition (2°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)	-	3.09 0.00 3.40
A) condition (-7°C)  B) condition (2°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)	- - [kW] -	3.09 0.00 3.40 4.03 0.00 3.11
A) condition (-7°C)  B) condition (2°C)	COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)	- - [kW] -	3.09 0.00 3.40 4.03 0.00 3.11 4.55
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)	COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)  Cdh (degradation coefficient)	- - [kW] -	3.09 0.00 3.40 4.03 0.00 3.11
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)	- [kW] - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)	COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COPd (declared COP)  Cdh (degradation coefficient)	- [kW] - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)  D) condition (12°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)	- [kW] - - [kW] - - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39 0.99
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)  D) condition (12°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)	- [kW] - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)  D) condition (12°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)	- [kW] - [kW] - [kW] - [c]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39 0.99 -10 4.79
(A) condition (-7°C)  (B) condition (2°C)  (C) condition (7°C)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)	- [kW] - [kW] - [kW] - [kW] - [kW] - [cC] - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39 0.99 -10 4.79 2.77
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)  D) condition (12°C)  (E) Tol (temperature operating limit)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)	- [kW] - [kW] - [kW] - [kW] - [kW] - [vC]	3.09  0.00 3.40  4.03  0.00 3.11  4.55  0.99 3.14  5.39  0.99 -10 4.79  2.77
(A) condition (-7°C)  (B) condition (2°C)  (C) condition (7°C)  (D) condition (12°C)  (E) Tol (temperature operating limit)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared heating capacity)  COP <sub>d</sub> (declared heating capacity)	- [kW] - [kW] - [kW] - [kW] - [kW] - [cC] - [kW]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39 0.99 -10 4.79 2.77 55 -7
A) condition (-7°C)  B) condition (2°C)  C) condition (7°C)  D) condition (12°C)  (E) Tol (temperature operating limit)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  WTOL (Heating water Operation Limit)	- [kW] - [kW] - [kW] - [kW] - [kW] - [vC]	3.09  0.00 3.40  4.03  0.00 3.11  4.55  0.99 3.14  5.39  0.99 -10 4.79  2.77
Part load conditions space heating average climate  (A) condition (-7°C)  (B) condition (2°C)  (C) condition (7°C)  (D) condition (12°C)  (E) Tol (temperature operating limit)  (F) No label found for faw.tbivalent.temperaturee.	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  WTOL (Heating water Operation Limit)  TblV  Pdh (declared heating capacity)	- [kW] - [kW] - [kW] - [kW] - [°C] [*C]	3.09 0.00 3.40 4.03 0.00 3.11 4.55 0.99 3.14 5.39 0.99 -10 4.79 2.77 55 -7
(A) condition (-7°C)  (B) condition (2°C)  (C) condition (7°C)  (D) condition (12°C)  (E) Tol (temperature operating limit)	COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  Cdh (degradation coefficient)  Tol (temperature operating limit)  Pdh (declared heating capacity)  COP <sub>d</sub> (declared COP)  WTOL (Heating water Operation Limit)	- [kW] - [kW] - [kW] - [kW] - [°C] [*C]	3.09  0.00 3.40  4.03  0.00 3.11  4.55  0.99 3.14  5.39  0.99 -10 4.79  2.77  55 -7  4.88

Details and precautions on installation, maintenance and assembly can be found in the installation and or operation manuals.

Energy labels and product fiches for additional combinations, packages and other products can be found on 'energylabel.daikin.eu.'

Sound power level in heating mode, measured according to the EN15036 for combustion boilers and EN 12102 for heat pumps under conditions of the EN ISO 3746, accuracy class 3 This data is for comparison of Energy efficiencies according to Regulation (EU) 2017/1369, for correct selection of products for your application, contact your dealer. Depending on your application and the product selected an additional supplementary heater may have to be installed.