



Product Service

Attestation of Conformity

No. N8A 072573 0055 Rev. 00

Holder of Attestation: FOSHAN GUANGTENG NEW ENERGY CO.,LTDSection 2,Yongfeng Industrial Zone
Lunjiao, Shunde,
528308 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA**Product: Heat pumps
(DC INVERTER HEAT PUMP)****Model(s): GT-SKR020KBDC-M290, GT-SKR030KBDC-M290,
GT-SKR040KBDC-M290, GT-SKR020KBDC-S290,
GT-SKR030KBDC-S290, GT-SKR040KBDC-S290.****Parameters:**
Rated Voltage: 220-240V~
Rated Frequency: 50Hz
Rated Power Input/Current:
GT-SKR020KBDC-M290, GT-SKR020KBDC-S290: 3050W/13,5A,
GT-SKR030KBDC-M290, GT-SKR030KBDC-S290: 4130W/18,2A,
GT-SKR040KBDC-M290, GT-SKR040KBDC-S290: 6030W/26,5A,
Protection Class: Class I
Degree of Protection: IPX4
Refrigerant: R290**Tested according to:**
EN 60335-1:2012/A15:2021
EN 60335-2-40:2003/A13:2012
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111230052901**Date,** 2023-04-04

(Sam Yang)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®